

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 3725-1305:124

Page 1 of 1

CATEGORY: Door Hardware (Fire-Rated)

LISTEE: Corbin Russwin, 225 Episcopal Rd., Berlin CT 06037-4004
Contact: Pradip Basu (860) 828-7377 *FAX (800) 659-7293

DESIGN: CORBIN RUSSWIN rim type Model ED5200A and mortise lock type Model ED5600A series fire exit hardware. Units feature a push action pushbar which retracts the latchbolts and deadbolt and unlock the door. Refer to listee's data sheet for additional detailed model descriptions and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as fire exit hardware for use on single outward swinging type 3-Hour fire rated door or pairs.

*Rev. 06-21-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**